

**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Vineland Public Charter School - Park Avenue

1015 Park Avenue
Vineland, NJ 08360

Results of Lead Analysis

Date & Time Sampled: 05/25/2017 06:55 - 06:59

Date & Time Analyzed: 05/31/2017 17:08 - 17:21

Date & Time Analyzed: 06/02/2017 15:05


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
VPCS-KC-KIT	19.7	15.5
VPCS-CS-RM3	<2.00	15.5
VPCS-KC-KIT (Flushed)	4.43	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterfest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Fax:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
PG6165	VPCS-FB	5/25/17	0655	D	1 x 250		First Draw Lead	FIELD BLANK
PG6166	VPCS-KC-KIT		0657	D	1 x 250		First Draw Lead	
PG6167	VPCS-CS-RM3		0659	D	1 x 250		First Draw Lead	
	end of samples			D	1 x 250		First Draw Lead	
				D	1 x 250		First Draw Lead	
				D	1 x 250		First Draw Lead	
				D	1 x 250		First Draw Lead	
				D	1 x 250		First Draw Lead	
				D	1 x 250		First Draw Lead	
				D	1 x 250		First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOIL SLISLUDGE GWAGROUND WATER SWSURFACE WATER WWWWASTE WATER

Turnaround Time <input checked="" type="checkbox"/> S-JWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	Report Format <input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Comments/Special Instructions <i>Preserve upon Receipt</i> Analyze flushed lead-sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	Cooler Temp Properly Preserved Yes No
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------------------------

Sampled by: (Print) James Eberts	Received by: (Signature) <i>James Eberts</i>	Date 5/26/17	Date 5/26/17	Time 1500
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____
Relinquished by: (Signature) _____	Received by: (Signature) _____	Date _____	Date _____	Time _____

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC

4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterlest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: Fax: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P66512	VPCS-KC-KIT	5/25/17	0658	D	1 x 250		Flushed Lead	
	VPCS-CS-RM3	↓	0700	D	1 x 250		Flushed Lead	
	end of samples			D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	<i>Preserve upon Receipt</i> Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	°C
		Yes	No

Sampled by: (Print) <i>James Eberts</i>	Received by: (Signature) <i>[Signature]</i>	Date 5/26/17	Date 5/26/17	Time 1500
Sampled by/Relinquished by: (Signature) <i>James Eberts</i>	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time